

**W A L C H E M**

IWAKI America Inc.

# **WDS Differential pH/ORP Sensor**

## **Instruction Manual**

# WALCHEM

IWAKI America Inc.

## Notice

© 2024 WALCHEM, Iwaki America Inc. (hereinafter “Walchem”)  
Five Boynton Road, Holliston, MA 01746 USA  
(508) 429-1110  
All Rights Reserved  
Printed in USA

## Proprietary Material

*The information and descriptions contained herein are the property of WALCHEM. Such information and descriptions may not be copied or reproduced by any means, or disseminated or distributed without the express prior written permission of WALCHEM, Five Boynton Road, Holliston, MA 01746.*

## Statement of Limited Warranty

*WALCHEM warrants equipment of its manufacture, and bearing its identification to be free from defects in workmanship and material for a period of 24 months for electronics and 12 months for mechanical parts and electrodes from date of delivery from the factory or authorized distributor under normal use and service and otherwise when such equipment is used in accordance with instructions furnished by WALCHEM and for the purposes disclosed in writing at the time of purchase, if any. WALCHEM’s liability under this warranty shall be limited to replacement or repair, F.O.B. Holliston, MA U.S.A. of any defective equipment or part which, having been returned to WALCHEM, transportation charges prepaid, has been inspected and determined by WALCHEM to be defective. Replacement elastomeric parts and glass components are expendable and are not covered by any warranty.*

*THIS WARRANTY IS IN LIEU OF ANY OTHER WARRANTY, EITHER EXPRESS OR IMPLIED, AS TO DESCRIPTION, QUALITY, MERCHANTABILITY, and FITNESS FOR ANY PARTICULAR PURPOSE OR USE, OR ANY OTHER MATTER.*

**180252 Rev I**  
**January 2024**

## TABLE OF CONTENTS

<b>1.0.....</b>	<b>INTRODUCTION .....</b>	<b>1</b>
<b>2.0.....</b>	<b>SPECIFICATIONS .....</b>	<b>1</b>
<b>3.0.....</b>	<b>UNPACKING &amp; INSTALLATION .....</b>	<b>2</b>
3.1 ....	UNPACKING THE UNIT .....	2
3.2 ....	GENERAL GUIDELINES .....	2
3.3 ....	INSTALLATION .....	3
3.4 ....	ICON DEFINITIONS .....	5
3.5 ....	ELECTRICAL INSTALLATION .....	5
<b>4.0.....</b>	<b>MAINTENANCE .....</b>	<b>7</b>
4.1 ....	CLEANING THE SENSOR .....	7
4.2 ....	REPLACING THE SALT BRIDGE .....	7
4.3 ....	IMPORTANT CONSIDERATIONS.....	8
<b>5.0 .....</b>	<b>TROUBLESHOOTING .....</b>	<b>8</b>

## 1.0 INTRODUCTION

The WDS Series of pH and ORP electrodes are differential sensors that are available with a choice of preamplifiers, one for Walchem controllers and another for certain other pH/ORP controllers. The differential measurement technique is reliable and immune to ground loop related problems.

This technique utilizes two glass electrodes to make the measurement differentially with respect to a third metal electrode. The second glass electrode is immersed in pH 7 buffer inside the electrode body, but electrically connected via a porous double junction salt bridge. If the internal solution becomes contaminated, the sensor may be rejuvenated by replacing the solution and salt bridge.

Four models of sensors are available:

WDS-PHW (for pH) and WDS-MVW (for ORP) contain a differential preamplifier that is compatible with Walchem controllers. These electrodes will have three twisted pairs plus a shield wire.

WDS-PHC (for pH) and WDS-MVC (for ORP) contain a differential preamplifier that is compatible with competitive, conventional pH/ORP controllers. These will have 5 wire cables with a shield wire.

The WDS Series are threaded at each end, allowing for both submersion and in-line mounting with a single electrode.

## 2.0 SPECIFICATIONS

### *Measurement Performance*

Ranges:	0 to 14 pH -2000 to +2000 mV -5 to 95 C (23 to 203 F)
Sensitivity:	0.001 pH 0.1 mV
Stability:	0.03 pH/day, non-cumulative 2 mV/day, non-cumulative

### *Mechanical*

Wetted materials:	PPS Body Ceramic reference junction Glass sensor Titanium palladium alloy ground rod FKM Platinum (ORP sensor only)
Cable length:	15 ft. (4.6m)
Maximum cable length:	1000 ft (305 m)
Pressure:	100 PSI (0.7 MPa) at 65 °C (149 °F) maximum
Temperature:	23 to 203°F (-5 to 95°C)
Dimensions:	7.1" x 2.14" x 2.14" (18 cm x 5.5 cm x 5.5 cm) 1 ½" NPTM pipe threads
Maximum Flow Rate:	10 feet/sec (3m/sec)

## **3.0 UNPACKING & INSTALLATION**

### **3.1 Unpacking the Unit**

Inspect the contents of the carton. Please notify the carrier immediately if there are any signs of damage to the sensor. Contact your distributor if any of the parts are missing. The carton should contain a WDS Series pH/ORP electrode and instruction manual. Any options or accessories will be incorporated as ordered.

### **3.2 General Guidelines**

Instructions for mounting the electrode into the process solution will vary greatly with the type of electrode and the circumstances that are encountered in your application. Here are some general guidelines to assist you. Refer also to the typical installation drawings.

The electrode should be mounted such that the measuring surfaces will always stay wet. If the electrode dries out, it will respond slowly to changing pH/ORP values for 24 hours, and if dried out repeatedly, will fail prematurely.

For submersion applications, mount the electrode below the minimum solution level. If the tank will be completely drained, plan on removing the electrode and storing it in tap water (NOT DI water) or pH 4 buffer solution while the tank is empty. If this is undesirable, a recirculation loop may be installed, and the electrode mounted in-line.

For in-line applications, where the electrode is installed in a pipe, the electrode should be placed on the discharge side of the pump (under positive pressure). A "U" trap should be installed so that if the flow stops, the electrode is still immersed in the solution. If the flow through the pipe cannot be stopped to allow for cleaning and calibration of the electrode, then the electrode should be placed in a by-pass line with isolation valves to allow for electrode removal. (Refer to installation drawings)

The electrode should be installed in an area where there is good solution movement and where it will respond rapidly to chemical additions. The placement of the electrode relative to the placement of chemical replenishment, along with the quality of the mixing, and the replenishment pump flow rate are each critical to accurate process control.

Avoid locations that are near sources of electrical noise (motor starters, power transformers, variable speed motor drives, radio transmitters, etc.), corrosive fumes or excessive moisture.

The electrode requires clearance of 6 cm (2.4") to remove it from an in-line tee.

### 3.3 Installation

**For submersion applications,** feed the cable through an appropriate length of 1" pipe with a 1" x 1 ½" NPTF reducing coupling at each end. Thread the electrode into one coupling, sealing the threads with Teflon tape. The cable is NOT immune to contact with the solution and must be protected! The opposite end of the pipe should be sealed against the cable with a water-tight cable gland.

If the cable length will exceed the supplied 15 feet (4.6 meter), it may be extended using 24 AWG or higher gauge, twisted pair, shielded cable and a watertight (NEMA 4X, IP67 or better) junction box. The shield wire must be continuous and grounded only at one point (normally inside the controller). If the junction box is grounded, DO NOT allow the shield wires to connect to ground inside the box.

Remove the protective caps from the measurement electrode and the salt bridge and immediately immerse the electrode in the solution to be measured. Do not allow the electrode to dry out!

**For in-line applications,** wrap the threads at the electrode end of the sensor with Teflon tape. Remove the protective caps from the measurement electrode and the salt bridge and immediately immerse the electrode in the solution to be measured by threading it into the 1 ½" NPTF process tee. Do not allow the electrode to dry out!

The sensor is designed for installation with the electrode end pointing down (at least 15 degrees above horizontal). DO NOT install it horizontally or with the electrodes pointing up.

If the cable length will exceed the supplied 15 feet (4.6 meter), it may be extended using 24 AWG or higher gauge, twisted pair, shielded cable and a watertight (NEMA 4X, IP67 or better) junction box. The shield wire must be continuous and grounded only at one point (normally inside the controller). If the junction box is grounded, DO NOT allow the shield wires to connect to ground inside the box.




Figure 1 Typical Installation

### 3.4 Icon Definitions

Symbol	Publication	Description
	IEC 417, No.5019	Protective Conductor Terminal
	IEC 417, No. 5007	On (Supply)
	IEC 417, No. 5008	Off (Supply)
	ISO 3864, No. B.3.6	Caution, risk of electric shock
	Pending	Caution, High temperature, risk of burn
	ISO 3864, No. B.3.1	Caution

### 3.5 Electrical Installation

**Note:** Proper grounding of this product is required. Any attempt to bypass the grounding will compromise the safety of persons and property.



**CAUTION!** There are live circuits inside the controller even when the power switch on the front panel is in the OFF position! The front panel must never be opened before power to the controller is REMOVED!



**CAUTION!** The electrical installation of the controller must be done by trained personnel only and conform to all applicable National, State and Local codes!

#### WDS-PHW and WDS-MVW Wiring

Wire Color	WebMaster	W400	W100/600/900/Intuition
Orange	IN+	IN+	IN+
Orange/White	IN-	IN-	IN-
Green	T+	T+	TEMP+
Green/White	T-	T-	TEMP-
Blue	+5	+5V	+5V
Blue/White	-5	-5V	-5V
Shield	Earth Ground	Earth Ground	SHIELD

## **WDS-PHC and WDS-MVC Wiring**

Most controllers that utilize the 5-wire conventional differential electrode have a color-coded terminal block that matches the color of the electrode cable. If not, please refer to the controller operating instruction manual for wiring directions.

Connect Black wire to BLK, Red to RED, Green to GRN, White to WHT, Yellow to YEL and the shield drain wire to SHLD.

## 4.0 MAINTENANCE

The WDS Series pH/ORP electrodes are ruggedly made and easy to maintain. Because the pH responsive glass bulb is relatively thin, care should be taken so that the bulb does not become scratched or broken. It is also important that ORP measuring surfaces are not scratched or gouged.

### 4.1 Cleaning the Sensor

The probe should be kept reasonably clean to avoid measurement errors. Frequency of cleaning can only be determined by experience. To clean proceed as follows:

Rinse with clean warm water.

Soak the end of the probe in warm water and dish detergent for 3 or 4 minutes.

Brush the end of the probe, particularly the three electrodes with a soft bristle brush such as a toothbrush. Take care not to scratch the glass electrode.

If the probe is still not clean, it may have to be cleaned with acid. *CAUTION: Do not acid clean probes used in processes containing cyanide solutions.* Some experimentation may be required to determine the most suitable acid for your process. Use the most dilute acid that is effective. Normally 10 parts of water to one part hydrochloric acid is sufficient. *Do not use hydrofluoric acid.*

Soak the probe for not more than 5 minutes in the chosen acid; then rinse thoroughly with clean warm water and soak in water for 3-5 minutes.

Calibrate the system in accordance with the instrument instruction manual.

### 4.2 Replacing the Salt Bridge

If the system can't be calibrated after cleaning the probe, it may be necessary to replace the standard cell solution.

Hold the probe vertically electrodes up. Put a 15 mm (9/16") crescent wrench around the salt bridge and turn counter-clockwise taking care not to damage the glass electrode. Discard the used salt bridge.

Up-end the probe and pour out the contents of the standard electrode chamber. Flush the chamber with a small amount of pH 7 buffer or clean water.

Refill the chamber with pH 7 buffer solution, up to the tip of the electrode, inside the chamber. DO NOT OVERFILL. It is important to leave space for the salt bridge thread and a small amount of air.

Screw the new salt bridge into the cavity until finger tight. Now turn 1/4 turn with the wrench. The front face of the salt bridge will stick out less than half an inch from the front of the probe.

### 4.3 Important Considerations

The pH electrode is shipped with plastic caps covering the sensing electrode and salt bridge. The caps contain a solution of pH adjusted salt solution. The electrode should remain stored with these caps full of solution.

Electrodes are a form of battery and have a limited shelf life. Electrodes in inventory should be rotated so older electrodes are used first.

Readings stabilize faster in some solutions than in others. Allow time for readings to stabilize. The temperature element can take as much as 15 minutes to equilibrate at the new temperature.

All pH electrodes age with time. Aging is characterized by shortened span and slower speed of response. Aging is best detected by performing a 2-point calibration.

Electrodes should be replaced when their readings cannot be corrected by the meter's controls and/or when their speed of response is too slow for the application for which they are being used.

The frequency of electrode replacement is a function of the application. Electrodes operating in hot liquids or at very high or low pH values will have shorter lives than those operating at neutral pH and ambient temperature will.

Coatings on the electrode's surface prevent new liquids from contacting its measuring surface and can mimic the effects of electrode aging. Before concluding that an electrode needs replacing, clean the electrode.

## 5.0 TROUBLESHOOTING

The probe can be checked by a few simple measurements. Two pH buffer solutions, pH 7 and either pH 4 or pH 10, and a multimeter are required. For ORP probes two calibration solutions, 200 and 600 mV, are required. Millivolt solutions may be  $\pm 20\%$  of nominal value. Actual value is noted on the bottle.

### WDS-PHC pH Electrodes

Clean the probe as described in Section 5.1. If the system cannot be calibrated, replace the salt bridge and pH 7 buffer solution as described in 5.2. If the system still can't be calibrated check the probe as follows:

Disconnect red, green, yellow and black wires at the junction box. If you are not using a junction box, disconnect at the instrument after shutting off the power.

Place the probe in pH 7 buffer. Allow enough time for the temperature of the probe and buffer to stabilize at room temperature.

Measure the resistance between the yellow and black wires to check the probe's temperature compensator. The resistance should be between 1000 to 1200 ohms at 25°C (78 °F). If the resistance is within specifications the probe's RTD is functioning correctly.

Reconnect the yellow and black wires and restore power to the instrument.

Measure the voltage between the red and green wires. If it is not within –50 to +50 millivolts with the probe in pH 7 buffer, the probe is defective. If the voltage is OK proceed to the next step.

Rinse the probe and place it in pH 4 or pH 10 buffer. Allow it to stabilize then check the voltage again between the red and green wires. If the voltage is between 100 and 230 millivolts (negative in pH 10 buffer, positive in pH 4 buffer) the probe is within specifications.

#### **WDS-MVC ORP Electrodes**

Rinse the probe and place it in 200 mV solution. The reading should be between 160 and 240 mV.

Repeat the above in a 600 mV solution. The reading should be between 560 mV and 640 mV.

#### **WDS-PHW pH Electrodes**

Clean the probe as described in Section 5.1. If the system cannot be calibrated, replace the salt bridge and pH 7 buffer solution as described in 5.2. If the system still can't be calibrated check the probe as follows:

Disconnect green, green/white, orange and orange/white wires at the junction box. If you are not using a junction box, disconnect at the instrument after shutting off the power.

Place the probe in pH 7 buffer. Allow enough time for the temperature of the probe and buffer to stabilize at room temperature.

Measure the resistance between the green and green/white wires to check the probe's temperature compensator. The resistance should be between 1000 and 1200 ohms at 25°C (78 °F). If the resistance is within specifications the probes RTD is functioning correctly.

Reconnect the green and green/white wires and restore power to the instrument.

Measure the voltage between the orange and orange/white wires. If it is not within –60 to +60 millivolts with the probe in pH 7 buffer, the probe is defective. If the voltage is OK proceed to the next step.

Rinse the probe and place it in pH 4 or pH 10 buffer. Allow it to stabilize then check the voltage again between the orange and orange/white wires. If the voltage is between 100 and 230 millivolts (negative in pH 10 buffer, positive in pH 4 buffer) the probe is within specifications.

#### **WDS-MVW ORP Electrodes**

Rinse the probe and place it in 200 mV solution. The reading should be between 160 and 240 mV.

Repeat the above in a 600 mV solution. The reading should be between 560 mV and 640 mV.



